



(Continued)

Page 2 of 3

SPECIAL GENERAL ELECTRIC DUAL FUEL SPACE HEATING SERVICE Rate 54

**FUEL CLAUSE:**

Bills are subject to an adjustment for cost of fuel as provided in Rate 58, or any amendments or alterations thereto.

**POWER FACTOR CLAUSE:**

The Company reserves the right to require the customer to install adequate equipment so that at all times it can operate its facilities to maintain a power factor between 90% lagging and 90% leading. If the customer operates outside this range, the maximum 15 minute reactive kilovolt amperes in excess of 50% of the maximum 15 minute kilowatt demand for the same month will be billed at \$1.75 per Kvar of such excess demand.

**DISCOUNT FOR PRIMARY SERVICE:**

A five percent discount shall be allowed if the customer provides his own transformers and related equipment and distribution facilities downstream of the meter, satisfactory to the Company, so that he can receive service and be metered at primary voltages of 2,400 volts or greater.

**CONTRACT TERMS:**

Customer agrees to contract for service under the Special General Electric Dual Fuel Space Heating Service rate for a minimum period of one year. At the end of a one year period, the customer will have the option of remaining under the Special General Electric Dual Fuel Space Heating Service rate or of returning to the applicable regular General Electric Service rate or applicable Optional Time-of-Day General Service rate.

**SPECIAL TERMS AND CONDITIONS:**

1. Electric space heating equipment shall be designed to operate at a nominal voltage of 208, 240, 277, or 480 volts, shall be separately metered and separately circuited, shall be permanently installed and the electric heating equipment shall be the primary source of space heating.
2. All installations must meet the minimum standards of the National Electrical Code so that the equipment will operate in a satisfactory manner and not interfere with other operations of the Company's system. Architects, contractors and electricians should consult with the Company before proceeding to design or erect installations for heating to make sure their equipment, insulation and building construction will meet requirements and receive adequate service.

(Continued)

**Date Filed:** June 26, 1986

**Effective Date:** For service rendered on and after July 8, 1986

**Issued By:** C. Wayne Fox, Vice President -  
Regulatory Affairs & General Services

